

KOWALSKI
Construction, Inc.

Corporate Office
2219 W. Melinda Ln.
Building A.
Phoenix, AZ 85027

Tel. 602.944.2645
Fax. 602.944.6844

www.kowalski.com
info@kowalski.com



Electrical 101 – Installation, Connectors & Protection - Chapter 7

Answers

1. The use of Metal Plates is required to protect cable in stud framing if it is closer than?
 - a) ¼"
 - b) 1"
 - c) 1 ¼"
 - d) None of the above

2. NM Cable is required to be stapled within?
 - a) 8" from a box without a connector
 - b) 12" from a box with connectors
 - c) Both A & B
 - d) Neither A or B

3. NM Cable should be stapled every?
 - a) 8"
 - b) 12"
 - c) 4 ½'
 - d) 5'

4. The radius of bend for NM Cable shall be greater than 5 times the cable diameter every 4 1/2'?
 - a) True
 - b) False



KOWALSKI
Construction, Inc.

Corporate Office

2219 W. Melinda Ln.
Building A.
Phoenix, AZ 85027

Tel. 602.944.2645
Fax. 602.944.6844

www.kowalski.com
info@kowalski.com



RESTORATION
AFFILIATES



5. It doesn't matter the size or quantity of the wires used in wire connectors as long as all exposed wires are in the connector?

a) True

b) False

6. Bonding and Grounding mean the same thing?

a) True

b) False

7. NM Cable should be stapled on the

a) Edge

b) Flat side

c) Either the edge or flat side

d) Neither the edge or flat side

